

Power Flow Analysis of the Enhanced Proposed 330kV Transmission Network of the Nigeria Grid

FESTUS OSAZEE AGBONTAEN*, JOEL OSARUMWENSE EGWAILE*, AND IGNATIUS KEMA OKAKWU*

RECEIVED N 25.03.2019 ACCEPTED ON 03.05.2019

ABSTRACT

The Nigeria's power sector transmission infrastructure continues to be challenged as it still remains the weak link in the electricity supply chain. The Nigerian Federal Government on its Roadmap for power sector reform highlighted that to accommodate the planned increase in generation capacity, there was need for a 30% increase in the "true deliverable" transmission capacity of the country's 330kV network. But the technical feasibility of this plan is an issue to be considered.

In this work, the existing 330kV Nigeria transmission network was expanded by the introduction of new lines and power stations, simulation was carried out and the effect was analyzed using Newton-Raphson algorithm in ETAP 12.6. The base case operating condition as obtained from the power flow on which the various transfer cases were implemented, gives a fair generation and loading pattern of the Nigerian grid. The total installed generating capacity of the base case considered was 11,948MW out of which 4,347.21MW was available for load level of 3,633.6MW. Result shows that the maximum load ability of the enhanced network was increased to 238.4% compared with the existing network when the Newton – Raphson iteration method was applied.

Key Words: Transmission Line, Network, Loadability, Load Flow, Maximum Load, Power Station.

1. INTRODUCTION

Electrical power systems are the backbone of any developing modern society, supporting several other critical infrastructures, such as transportation, communication, water, etc. [1]. However, increase in economic activities resulting from increase in population and social advancement has led to increase in electrical energy demand. This has increased the burden on the existing transmission assets and in some cases, has caused the loading of the transmission assets beyond

their design limits with consequent reduction in power quality and power outages in extreme cases [2].

The current transmission system in Nigeria comprises 5523.8 km of 330 kV, 6801.49 km of 132 kV, 32 No. 330/132 kV substations with total installed transformer capacity of 7688 MVA. 105 No. 132/33/11 kV substations with total installed transformer capacity of 9130 MVA. The average available capacity on 330/132 kV is 7364 MVA and 8448

Authors E-Mail: (festus.felix2326@gmail.com, egwaile.joel@uniben.edu, igokakwu@yahoo.com)

* Department of Electrical/Electronic Engineering, University of Benin, Benin City, Nigeria.

MVA on 132/33 kV [3]. Some of the major challenges associated with the South-South, South East and South West regions (Edo, Delta, Bayelsa, Rivers, AkwaIbom, Cross River, Abia, Enugu, Anambra, Imo, Ebonyi, Oyo, Osun, Ekiti, Ondo and Ogun States) of the transmission network are over voltages due to reactive power generation from the various power plants within the vicinity. And power is stranded due to the proximity of most of the gas thermal power stations and inadequacy of the tie lines to evacuate load. Lagos (Lagos State) south west region is prone to transmission congestion [3-4]. The grid bus is characterized by poor voltage profile in most parts of the network, frequent system collapse and exceedingly high transmission losses [5-6]. Furthermore, many electric networks in developing countries are facing the problem of voltage drop and energy loss, deterioration and overloaded with unbalanced loads [7]. Thus, there is need to have a sustainable, reliable and stable supply to create an enabling balanced economy [8]. The unreliability of the System Network has impacted on the nation's socio-economic development and industrialization hence, the recent launch of the roadmap of the power sector reform by the Federal Government [9].

In order to increase power, there is a need to use all our sustainable energy sources like hydro, gas, wind, solar, and coal [10]. The reform also sought the maximization of access to electricity services, by promoting and facilitating consumer connections to the network systems in both rural and urban areas [11]. Energy planning experts using modern energy modeling tools estimate that for the Nigerian economy to grow at a rate of 10% the country's electricity requirement by 2020 will be of the order of 30,000 MW, and by 2030 it will be 78,000 MW [12].

2. METHODOLOGY

Data was collected from TCN (Transmission Company of Nigeria) for load flow analysis. The analysis on the data was done using Newton – Raphson algorithm in ETAP 12.6 load flow analyzer which is a power system modeling, design, analysis, optimization, control, and automation software.

Newton – Raphson method for load flow studies was used to simulate and investigate the generated power of the network. The load flow program calculates the magnitude and phase angle of the voltage at each bus, real and reactive power flowing in each line respectively.

A number of methods for power flow calculation use equations in different forms considering sending end (i^{th} end) or receiving end (j^{th} end). In this work, we used the same method in section 2.26 of [13] where a detailed explanation of Newton-Raphson method as applicable to power flow problem was given.

The linear equation in compact form used is given as:

$$\begin{pmatrix} \Delta P \\ \Delta Q \end{pmatrix} = \begin{pmatrix} J_1 & J_2 \\ J_3 & J_4 \end{pmatrix} \begin{pmatrix} \Delta \delta \\ \Delta V \end{pmatrix} \quad (1)$$

Enhancement of the network was done based on the transmission planning region: South – East region (Anambra, Imo, Rivers, Akwa Ibom, Abia, Cross River, Enugu and Ebonyi), South – South region (Edo, Delta and Bayelsa), South – West region (Kwara, Oyo, Osun, Ekiti, Ondo and Ogun), Lagos region, North – West Region (Sokoto, Kebbi and Zamfara), North Region (Kastina, Jigawa and Kano), North – East Region (Yoba, Bornu, Gombe, Bauchi, Plateau and Taraba) and Central Region (Abuja, Kaduna, Niger, Nasarawa and Kogi) [14].

3. PRESENTATION OF SYSTEM DATA

The data used in this work is as presented in Tables 1-2. Twenty (20) generating stations, Sixty-Seven (67)

transmission lines and a total of Fifty-Nine (59) buses stations with Thirty (30) load buses were considered for the existing network. The network was further expanded by adding the transmission lines presented in Table 3.

TABLE 1. EXISTING 330KV TRANSMISSION LINE NETWORK CIRCUIT

No.	From Station Location	To Station Location	Number of Circuits	Length (Km)	No.	From Station Location	To Station Location	Number of Circuits	Length (Km)
1.	Afam GS	Alaoji T.S	2	25	35.	Ikot - Ekpene T.S	Alaoji T.S	2	57.9
2.	Afam GS	PH main T.S	2	8	36.	Ikot - Ekpene T.S	Odukpani T.S	2	88.5
3.	Ahoda T.S	Gbarian GS	2	87.4	37.	Jebba G.S	Jebba T.S	2	8
4.	Aiyede T.S	Olorunsogo GS	1	125	38.	Jebba T.S	Ganmo T.S	1	70
5.	Ajah T.S	Lekki T.S	2	5.5	39.	Jebba T.S	Osogbo T.S	2	157
6.	Ajah T.S	Alagbon T.S	2	21	40.	Jebba T.S	Shiroro GS	2	244
7.	Ajaokuta T.S	Geregu GS	1	75	41.	Jos T.S	Makurdi T.S	1	285
8.	Aladjia T.S	Sapele GS	1	93	42.	Kaduna T.S	Shiroro GS	2	95
9.	Alagbon T.S	Lekki T.S	2	24.5	43.	Kaduna T.S	Kano T.S	1	230
10.	Alaoji GS	Alaoji T.S	2	50	44.	Kaduna T.S	Jos T.S	1	197
11.	Alaoji T.S	Owerri T.S	2	77.1	45.	Kainji T.S	Kainji GS	2	0.47
12.	Asaba T.S	Onitsha T.S	2	65.8	46.	Kainji T.S	Jebba T.S	2	81
13.	Benin T.S	Ajaokuta T.S	2	195	47.	Katampe T.S	Gwagwalada T.S	1	60
14.	Benin T.S	Delta GS	1	107	48.	lokoja T.S	Ajaokuta T.S	1	215
15.	Benin T.S	Sapele GS	2	50	49.	New Haven T.S	Ugwaji T.S	2	65
16.	Benin T.S	Asaba T.S	2	153.9	50.	New Haven T.S	Onitsha T.S	1	96
17.	Birnin - Kebbi T.S	Kainji T.S	1	310	51.	Odukpani T.S	Adiabor T.S	2	10
18.	Damaturu T.S	Maiduguri T.S	1	260	52.	Okearo T.S	Egbie T.S	2	30
19.	Delta GS	Aladjia T.S	1	30	53.	Omotosho GS	Benin T.S	1	120
20.	Egbie GS	Benin T.S	1	218	54.	Onitsha T.S	Okpai GS	2	56
21.	Egbie GS	Aja T.S	2	14	55.	Onitsha T.S	Alaoji T.S	1	138
22.	Ganmo T.S	Osogbo T.S	1	87	56.	Osogbo T.S	Aiyede T.S	1	119
23.	Gbarian GS	Yenegoa T.S	2	25	57.	Osogbo T.S	Ikeja west T.S	1	235
24.	Gombe T.S	Damaturu T.S	1	160	58.	Osogbo T.S	Ihovbor GS	1	251
25.	Gombe T.S	Yola T.S	1	240	59.	Owerri T.S	Ahoda T.S	2	73.6
26.	Gwagwalada	Shiroro GS	1	144	60.	PH main T.S	Omoko T.S	2	83
27.	Gwagwalada T.S	Lokoja T.S	1	135	61.	Sapele GS	Delta GS	1	93
28.	Ihovbor GS	Benin T.S	1	20	62.	Shiroro GS	Katampe T.S	1	144
29.	Ikeja west T.S	Akangba T.S	2	18	63.	Paras energy T.S	Sagamu T.S	2	4
30.	Ikeja west T.S	Omotosho T.S	1	160	64.	Trans amadi T.S	PH main T.S	2	8
31.	Ikeja west T.S	Okearo T.S	2	32	65.	Egbie GS	Ikorodu T.S	2	17
32.	Ikeja west T.S	Egbie T.S	1	62	66.	Ikorodu T.S	Sagamu T.S	2	34
33.	Ikeja west T.S	Olorunsogo GS	1	50	67.	Asco GS	Ajaokuta T.S		50
34.	Ikot - Ekpene T.S	Ugwaji T.S	2	174			Total		6717.67

4. DISCUSSION OF RESULT FROM THE ANALYZED NETWORK.

The maximum load the existing network when subjected to various loading conditions is 4,948.78MW and 1,448.72MVar for a base load of 4,347.21MW and 738.978MVar with losses of 246.253MW. And Damaturu T.S (0.82p.u), Gombe T.S (0.82p.u), Jos T.S (0.84p.u), Kaduna T.S (0.81p.u), Kano T.S (0.81p.u), Katempa T.S (0.82p.u) and Yola T.S (0.81p.u) violated the statutory voltage limit of 0.85p.u - 1.05p.u [15]. However, the expanded network according to the transmission

planning region was simulated and analyzed to determine the performance effect when enhanced to allow more power to be evacuated within the network.

The load carrying capacity of the network was determined by using ETAP 12.6 Load flow Analyzer to simulate the 330kV expanded/proposed network consisting of seventy-six (76) buses, ninety-three (93) transmission lines and thirty (30) generating stations (18,975MW installed generating capacity). The input data used in the simulation of the maximum load capacity include various line loading and generation as obtained from TCN which represents the base case for the model.

TABLE 2. BUS LOADING

No.	Terminal Bus	Rating (MVA)
1.	Afam	105.882
2.	Aiyede T.S	117.647
3.	Aja T.S	58.824
4.	Ajaokuta T.S	117.647
5.	Akangba T.S	131.765
6.	Aladja T.S	96.588
7.	Alaoji T.S	117.647
8.	Alaoji G.S	52.588
9.	Benin T.S	184.471
10.	Birni-Kebbi T.S	117.647
11.	Delta	75.647
12.	Egbin G.S	1176.471
13.	Ganmo T.S	75.882
14.	Geregu NIPP & GS	164.706
15.	Gombe T.S	235.294
16.	Ikeja West T.S	352.941
17.	Jebba T.S	10.118
18.	Jebba G.S	117.647
19.	Jos T.S	352.941
20.	Kaduna T.S	195.529
21.	Kainji G.S	117.647
22.	Kano T.S	217.529
23.	Katampe T.S	235.294
24.	Maiduguri T.S	58.824
25.	New Haven T.S	294.118
26.	Okaero T.S	117.647
27.	Okpia G.S	11.765
28.	Onitsha T.S	135.529
29.	Oshogbo T.S	176.471
30.	Shiroro G.S	72.353
31.	Yola T.S	117.647

Electric power transfer was investigated by the insertion of the following power station; Calabar (561MW), Ibom (191MW), Aba (140MW), Azura(450MW), Kano (500MW), Mambilla (3,050MW), Zungeru (700MW), Itobe (1,200MW), Kiri (35MW) and Zamfara (100MW) into the network which increased the total installed capacity from 11,948-18,975MW (i.e. 58.81% increase). The network was further expanded by adding the transmission lines shown in Table 3 to ascertain the maximum load carrying capacity of the network.

Results show that the network was able to evacuate 16,746.859MW (238.4% maximum loadability increase) and 8,025.291MVar with loading of 16,400.067MW and 10,163.847MVar and Dandikowa T.S (0.80p.u) was out of the statutory voltage limit of 0.85-1.05p.u. as seen in the power flow result in Table 4 and voltage profile diagram presented in Fig. 1. However, it was observed that the total losses on the transmission network is 252.25MW as shown in the line flow result presented in Table 5. Fig. 2, shows section of the simulation diagram of the network modeled on ETAP 12.6.

TABLE 3. TRANSMISSION LINES ADDED TO THE EXISTING NETWORK

No.	Transmission Line	Length (K.m)	Number of Circuits)
1.	Ikot Ekpene T.S - Ibom GS	2.4	Double
2.	Ikot Ekpene T.S - Afam GS	107.8	
3.	Aba GS - Alaoji T.S	14	
4.	Ibom GS - Eket T.S	37.4	
5.	Ikot Ekpene T.S - Calabar GS	71	
6.	Egbema T.S - Owerri T.S	5	
7.	Eket T.S - Itu T.S	75	
8.	Itu T.S - Aba T.S	74.7	
9.	Adiabor T.S - Itu T.S	10	
10.	Omotosho GS - Ajah T.S	145	
11.	Kaduna T.S - Jos T.S	217.5	
12.	Birni - Kebbi T.S - Sokoto T.S	162	
13.	Sokoto T.S - Kastina T.S	162.6	
14.	Kastina T.S - Kano GS	171	
15.	Kano GS - Damaturu T.S	429.9	
16.	Maiduguri T.S - Yola T.S	165	
17.	Gwagwalada T.S - Lafia T.S	223.2	
18.	Gombe T.S - Dadinkowa T.S	368.2	
19.	Makurdi T.S - Mambilla GS	354	
20.	Mambilla GS - Jalingo T.S	179	
21.	Zungeru GS - Gwagwalada T.S	181.4	
22.	Yola T.S - Kiri GS	5	
23.	Yola T.S - Jalingo GS	165	

Power Flow Analysis of the Enhanced Proposed 330kV Transmission Network of the Nigeria Grid

TABLE 4. POWER FLOW RESULT OF THE ENHANCED NETWORK

No.	Bus ID	V (p.u)	Pgen (MW)	Qgen (Mvar)	Pload (MW)	Qload (Mvar)	No.	Bus ID	V (p.u)	Pgen (MW)	Qgen (Mvar)	Pload (MW)	Qload (Mvar)
1.	Aba T.S	1.02	0	0	0	0	40.	Jebba T.S	1	0	0	622.5	385.79
2.	Adiabor T.S	1.02	0	0	0	0	41.	Jos T.S	0.96	0	0	413.9	256.54
3.	Aes GS	0.98	236.27	160.26	121.17	75.09	42.	Kaduna T.S	1.01	0	0	55.84	34.604
4.	Afam GS	1.03	597.81	234	285.75	177.1	43.	Kainji GS	1.02	672.4	332.04	509.9	316.03
5.	Ahoda T.S	1.03	0	0	0	0	44.	Kainji T.S	1.02	0	0	0	0
6.	Aiyede T.S	0.96	0	0	167.37	103.7	45.	Kano GS	1.01	496.64	227.16	562.3	348.5
7.	Aja T.S	0.97	0	0	34.321	21.27	46.	Kastina T.S	0.95	0	0	211.5	131.09
8.	Ajaokuta T.S	1.04	0	0	194.9	120.8	47.	Katampe T.S	0.96	0	0	384.5	238.27
9.	Akangba T.S	0.88	0	0	157.59	97.67	48.	Kiri GS	0.95	27.717	16.023	326.7	202.47
10.	Aladja T.S	0.96	0	0	330.67	204.9	49.	Lafia T.S	0.96	0	0	202.5	125.47
11.	Alagbon T.S	0.97	0	0	34.295	21.25	50.	Lekki T.S	0.97	0	0	0	0
12.	Alaoji GS	1.04	862.03	393.58	197.8	122.6	51.	Lokoja T.S	1.05	0	0	0	0
13.	Alaoji T.S	1.02	0	0	564.85	350.1	52.	Maiduguri T.S	0.97	0	0	103.3	64.032
14.	Asaba T.S	1.02	0	0	0	0	53.	Makurdi T.S	1.03	0	0	193.7	120.05
15.	Asco GS	1.02	39.356	17.783	190.05	117.8	54.	Mambilla GS	1.05	2637.7	1146.2	1388	860.39
16.	Azura GS	1.04	384.75	167.02	196.87	122	55.	New Haven T.S	1.02	0	0	202.8	125.69
17.	Benin T.S	1.04	0	0	194.9	120.8	56.	Odukpani GS	1.02	212.78	131.01	282.4	175.02
18.	Birni-Kebbi T.S	0.98	0	0	121.67	75.4	57.	Okaero T.S	0.92	0	0	230.9	143.09
19.	Calabar GS	1.07	543.2	333.79	257.58	159.6	58.	Okpia GS	1.04	362.67	190.57	19.45	12.054
20.	Dadinkowa T.S	0.8	0	0	230.46	142.8	59.	Olorunsogo GS	1.04	935.13	476.87	0	0
21.	Damaturu T.S	1.04	0	0	0	0	60.	Omoko GS	1.04	350.67	187.75	388.6	240.86
22.	Delta GS	1	787.96	339.8	216.94	134.4	61.	Omotosho GS	0.98	710.35	416.06	0	0
23.	Egbema GS	1.04	316.68	135.5	195.12	120.9	62.	Onitsha T.S	1.01	0	0	520.5	322.59
24.	Egbin GS	0.97	1065.5	589.27	170.2	105.5	63.	Oshogbo T.S	0.97	0	0	255.3	158.21
25.	Eket T.S	1.02	0	0	0	0	64.	Owerri T.S	1.03	0	0	0	0
26.	Ganmo T.S	0.96	0	0	199.39	123.6	65.	Paras energy GS	0.99	44.041	29.013	0	0
27.	Gbarain GS	1.01	109.83	57.148	184.06	114.1	66.	PH main T.S	1.03	0	0	0	0
28.	Geregu GS	1.05	763.15	355.23	277.14	171.8	67.	Sagamu T.S	0.99	0	0	0	0
29.	Gombe T.S	0.95	0	0	164.18	101.8	68.	Sapele GS	1.05	1313.9	604.36	503.5	312.06
30.	Gwagwalada T.S	1.02	0	0	0	0	69.	Shiroro GS	1.03	537.43	204.05	270.8	167.83
31.	Ibom GS	1.03	76.176	39.934	0	0	70.	Sokoto T.S	0.93	0	0	297.7	184.48
32.	Ihovor GS	1.04	356.22	151.22	197.44	122.4	71.	Trans amadi GS	1.02	158.18	72.989	190.1	117.8
33.	Ilaje West T.S	0.89	0	0	1141.8	707.6	72.	Ugwuaji T.S	1.02	0	0	0	0
34.	Ikorodu T.S	0.99	0	0	0	0	73.	Yenegoa T.S	1	0	0	180.9	112.14
35.	IkotEpkene T.S	1.03	0	0	286.09	177.3	74.	Yola T.S	0.95	0	0	32.84	20.354
36.	Itobe GS	1.05	1000.5	503.29	502.33	311.3	75.	Zamfara GS	1	86.218	45.584	273.8	169.71
37.	Itu T.S	1.01	0	0	371.4	230.2	76.	Zungeru GS	1.04	592.46	246.16	393.9	244.09
38.	Jalingo T.S	0.98	0	0	172.87	107.1	Total			16747	8025.3	16400	10164
39.	Jebba GS	1	469.11	221.64	22.39	13.877							

TABLE 5. LINE FLOW RESULT OF THE ENHANCED NETWORK

No.	From Bus	To Bus	P Losses (MW)	Q Losses (Mvar)	No.	From Bus	To Bus	P Losses (MW)	Q Losses (Mvar)
1.	Aba T.S	Alaoji T.S	0.01	-9.92	48.	Ikeja West T.S	Okaero T.S	6.63	11.11
2.	Aba T.S	Itu T.S	0.09	-52.43	49.	Ikorodu T.S	Sagamu T.S	0.04	-0.89
3.	Adiabor T.S	Odupkani GS	0.43	-5.15	50.	IkotEpkene T.S	Afam GS	0.03	-1.01
4.	Adiabor T.S	Itu T.S	0.44	-5.08	51.	IkotEpkene T.S	Ugwuaji T.S	4.03	-106.67
5.	Afam GS	PH main T.S	0.11	-5.27	52.	IkotEpkene T.S	Alaoji T.S	0.09	-41.14
6.	Ahoda T.S	Gbarain GS	0.53	-59.62	53.	Itobe GS	Lokoja T.S	0.78	-4.08
7.	Aiyede T.S	Olorunsogo GS	6.54	-22.68	54.	Itu T.S	Eket T.S	0.23	-52.3
8.	Aja T.S	Lekki T.S	0	-3.57	55.	Jalingo T.S	Yola T.S	8.15	-68.28
9.	Aja T.S	Alagbon T.S	0	-13.61	56.	Jebba GS	Jebba T.S	0.14	-4.88
10.	Ajaokuta T.S	Benin T.S	0.85	-140.15	57.	Jebba T.S	Ganmo T.S	3.21	-7.31
11.	Ajaokuta T.S	Geregu GS	1.15	-125.08	58.	Jebba T.S	Oshogbo T.S	2.22	-94.95
12.	Akangba T.S	Ikeja West T.S	0.42	-7.81	59.	Jebba T.S	Shiroro GS	0.36	-171.83
13.	Aladjia T.S	Delta GS	5.33	15.09	60.	Jos T.S	Makurdi T.S	5.59	-169.31
14.	Alagbon T.S	Lekki T.S	0	-15.89	61.	Kaduna T.S	Shiroro GS	11.77	-16.65
15.	Alaoji GS	Alaoji T.S	6.41	-8.44	62.	Kaduna T.S	Jos T.S	7.8	-110.55
16.	Alaoji T.S	Onitsha T.S	0.32	-44.98	63.	Kainji T.S	Kainji GS	0.03	-0.2
17.	Alaoji T.S	Owerri T.S	0.11	-54.87	64.	Kainji T.S	Jebba T.S	1.95	-48.33
18.	Alaoji T.S	Afam GS	0.19	-17.08	65.	Kano GS	Damaturu T.S	7.18	-278.14
19.	Asaba T.S	Benin T.S	1.53	-93.06	66.	Kano GS	Kaduna T.S	0.12	-76.64
20.	Asaba T.S	Onitsha T.S	0.95	-42.34	67.	Kastina T.S	Sokoto T.S	1.29	-92.41
21.	Asco GS	Ajaokuta T.S	0.56	-33.97	68.	Kastina T.S	Kano GS	10.87	-63
22.	Azura GS	Benin T.S	0.56	-30.91	69.	Kiri GS	Yola T.S	0.12	-2.57
23.	Benin T.S	Sapele GS	4.81	-16.42	70.	Lafia T.S	Gwagwalada T.S	5.51	-126.59
24.	Benin T.S	Delta GS	0.72	-33.1	71.	Lokoja T.S	Ajaokuta T.S	1.37	-155.09
25.	Benin T.S	Egbin GS	1.41	-65.62	72.	Maiduguri T.S	Yola T.S	1.21	-99.75
26.	Benin T.S	Omotosho GS	1.75	-32.04	73.	Makurdi T.S	Ugwuaji T.S	2.01	-181.61
27.	Birni-Kebbi T.S	Kainji T.S	7.49	-67.38	74.	Mambilla GS	Makurdi T.S	12.48	-205.98
28.	Calaabar GS	IkotEpkene T.S	4.21	-34.38	75.	Mambilla GS	Jalingo T.S	21.93	-26.2
29.	Dadinkowa T.S	Gombe T.S	17.28	-116.26	76.	New Haven T.S	Onitsha T.S	1.39	-25.92
30.	Damaturu T.S	Maiduguri T.S	0.8	-83.39	77.	Odupkani GS	IkotEpkene T.S	0.05	-63.26
31.	Egbin GS	Aja T.S	0.15	-8.4	78.	Okaero T.S	Egbin GS	13.25	39.67
32.	Egbin GS	Aes GS	0.68	-9.99	79.	Okpia GS	Onitsha T.S	6.08	-13.4
33.	Egbin GS	Ikorodu T.S	1.52	-27.69	80.	Omoku GS	PH main T.S	1.59	-53.24
34.	Ganmo T.S	Oshogbo T.S	0.08	-26.12	81.	Omotosho GS	Aja T.S	0.44	-11.8
35.	Gbarain GS	Yenegoa T.S	0.57	-14.68	82.	Oshogbo T.S	Aiyede T.S	0.06	-36.1
36.	Gombe T.S	Yola T.S	2.5	-59.88	83.	Oshogbo T.S	Ihovor GS	3.83	-65.97
37.	Gombe T.S	Kaduna T.S	10.54	-32.78	84.	Owerri T.S	Ahoda T.S	0.02	-3.52
38.	Gombe T.S	Damaturu T.S	4.68	-30.92	85.	Owerri T.S	Egbema GS	0.79	-73.34
39.	Gwagwalada T.S	Shiroro GS	0.03	-49.91	86.	Paras energy GS	Sagamu T.S	0.11	-2.23
40.	Gwagwalada T.S	Lokoja T.S	5.36	-76.45	87.	Sapele GS	Delta GS	3.4	-16.56
41.	Gwagwalada T.S	Katampe T.S	6.34	9.71	88.	Shiroro GS	Katampe T.S	3.18	-32.42
42.	Ibom GS	Eket T.S	0.06	-26.7	89.	Sokoto T.S	Birni-Kebbi T.S	3.85	-83.86
43.	Ibom GS	IkotEpkene T.S	0.04	-1.55	90.	Trans amadi GS	PH main T.S	0.02	-5.67
44.	Ihovor GS	Benin T.S	0.15	-27.74	91.	Ugwuaji T.S	New Haven T.S	0.12	-4.12
45.	Ikeja West T.S	Olorunsogo GS	13.9	17.81	92.	Zamfara GS	Birni-Kebbi T.S	4.58	-185.57
46.	Ikeja West T.S	Egbin GS	8.78	22.76	93.	Zungeru GS	Gwagwalada T.S	3.41	-117.43
47.	Ikeja West T.S	Omotosho GS	11.56	35.94	Total			252.25	

Power Flow Analysis of the Enhanced Proposed 330kV Transmission Network of the Nigeria Grid




FIG. 1. VOLTAGE PROFILE OF THE ENHANCED NETWORK




FIG. 2. SECTION OF THE LOAD FLOW SIMULATION DIAGRAM MODELED ON ETAP 12.6 EDIT MODE

5. CONCLUSION

In this work, the system profile analysis revealed that the existing network evacuated more power when more power station and transmission lines were added for the purpose of system expansion. The maximum power the network evacuated was 16,746.859MW and 8,025.291MVar with loading of 16,400.067MW and 10,163.847MVar. Nigeria grid network can only evacuate between 1,000 and 4,000MW due to inefficiency, unreliability, not properly ringed network, high losses and power station breakdown. From the analysis, more generating stations and transmission lines should be built and added to the network and the single circuit lines should be upgraded to double circuit lines in order to boost generation and transmission, while control devices should be used in high and low voltage areas.

ACKNOWLEDGEMENT

The authors are grateful to Prof. SA Ike, Department Electrical/Electronic Engineering, Faculty of Engineering, University of Benin, Benin City, for his assistance and supervision throughout the period this work was done.

REFERENCES

- [1] Mathaios, P., Dimitris, N.T., Pierluigi, M., and Nikos, D.H., "Power Systems Resilience Assessment: Hardening and Smart Operational Enhancement Strategies", Proceedings of IEEE, Volume 105, No. 7 , pp 1-11, 2017.
- [2] Emmanuel, U.O., Samuel, N.N., and Gerald, K.I., "Electric Power Transmission Enhancement: A Case of Nigerian Electric Power Grid", American Journal of Electrical and Electronic Engineering, Volume 4, No. 1, pp. 33-39, 2016.
- [3] Oshevire, P., Oladimeji, T., and Onohaebi, S., "Smart Grid Technology and its Possible Applications to the Nigeria 330 kV Power System", Smart Grid & Renewable Energy, Volume 4, pp. 391-397, 2013.
- [4] Sunday, O.O., and Friday, O.O., "Empirical Modeling of Power Losses as a Function of Line Loadings and Lengths in the Nigerian 330 kV Transmission Lines", International Journal of Academic Research, Volume 2, pp. 47-53, 2010.
- [5] Utazi, D.N., and Ujam, A.T., "The Need to Expand and Modernize the Electricity Transmission Infrastructure in Nigeria", International Journal of Engineering Trends and Technology, Volume 12, No. 8, pp. 411 413, 2014.
- [6] Oriaifo, A.P., and Orukpe, P.E., "Analysis of Voltage Collapse in Power Systems", Journal of Electrical and Electronic Engineering, Volume 13 No. 1, pp. 16-24, Nigeria, 2016.
- [7] Hasham, K., and Mohammad, A.C., "Performance Enhancement of Low Voltage Distribution Network in Developing Countries using Hybrid Rehabilitation Technique", Mehran University Research Journal of Engineering & Technology, Volume 37, No. 3, pp. 493-512, Jamshoro, Pakistan, July 2018.
- [8] Igbinovia, S.O., and Orukpe, P.E., "Rural Electrification: The Propelling Force for Rural Development of Edo State, Nigeria", Journal of Energy in Southern Africa, Volume 18, No. 3, pp. 18-26, 2007.
- [9] Onohaebi, O.S., "Power Outage in the Nigeria Transmission Grid", Research Journal of Applied Sciences, Volume 4, No. 1, pp. 1-9, 2009.
- [10] Babatunde R.F., "Power Sector Reforms-Challenges and the Way Forward", 2017 <http://thenewsnigeria.com.ng/2017/07/power-sector-reform-challenges-and-the-way-forward/> Accessed:20/4/19.
- [11] The Nation, "Electricity: Challenges and Prospects", 2017 <http://www.nigeriaelectricityhub.com/2017/03/10/electricity-challenges-and-prospects/>.Accessed: 25/4/19.

- [12] Abubakar, S.S., “The Way Forward for Electricity Supply in Nigeria”, Nigerian National Committee of the World Energy Council, 2015 <http://voices.nationalgeographic.com/2015/10/20/the-way-forward-for-electricity-supply-in-nigeria/>. Accessed: 25th April, 2019.
- [13] Onah, J.N., “Contingency Evaluation of the Nigerian 330kV Transmission Grid”, University of Nigeria, Nsukka, M.E. Thesis, pp. 33-39, 2015.
- [14] Transmission Company of Nigeria, “Transmission Plans (2013-2017) and Evacuation of Niger Delta Power Holding Company (NDPHC) Power Plants Generation”, Presidential Task Force on Power Summit, Abuja. pp. 4-19, 2013.
- [15] Agbontaen, F.O., and Ike, S.A., “Loadability Analysis of the Existing 330kV Transmission Network of the Nigerian Electricity Grid”, Nigerian Research Journal of Engineering and Environmental Sciences, Volume 2 No. 2, pp. 416-423, 2017.